

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60132326

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

0001--27141419 001

29.08.2018

(day/mo/yr)

Genehmigungsinhaber *License Holder*

BEŞ A ELEKTRİK VE ELEKTRONİK
SAN. VE TIC. LTD. ŞTİ
ÇENGELDERE MAH. ÇENGELDERE CAD. NO:105
KAT:2 ÇAVUŞBAŞI
BEYKOZ - İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

BEŞ A ELEKTRİK VE ELEKTRONİK
SAN. VE TIC. LTD. ŞTİ
ÇENGELDERE MAH. ÇENGELDERE CAD. NO:105
KAT:2 ÇAVUŞBAŞI
BEYKOZ - İSTANBUL
Türkiye

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111216585

Geprüft nach *Tested acc. to*

IEC 61347-2-7:2011+A1/10.17
IEC 61347-2-13:2014+A1
IEC 61347-1:2015+A1

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

LED Module (Emergency Lighting LED Controlgear)

Type Designation:	EMLUS-SLED/X/Y	10
X: Max. Output Voltage can be ;	a) M075, b) M150, c) M050,	1
d) H040, e) H060, f) H090, g) H150		
Y: Rated duration of operation;	1H or 3H	1
Trademark:	5eşA	
Rated Voltage:	230V AC	
Frequency:	50/60 Hz	
Ambient temperature (ta):	-10°C... +50°C	
Rated maximum temperature:	(tc): 70°C	
Output Voltage Range:	a) 3-75V DC	
	b), g) 3-150V DC; c) 3-50V DC;	
	d) 3-40V DC; e) 3-60V DC; f) 3-90V DC	
Protection class:	IP20	
Usable LED Driver max output power	1.5A and 60W.	
Insulation Class:	II	
For EOFI ratings refer to test report.		

12

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Sahure Oralalp